



To

The Principal,
Govt. Model Sanskriti Sr. Sec. School,
Police Line, Ambala City.

No. 45 Dated: 2/11/2023

Subject: Regarding Structure Safety Certificate for CBSE Affiliation.

Reference: Your office Letter No. 272 / 22 dated 17.11.2022.

The School Building i.e. Govt. Model Sanskriti Sr. Sec. School, Police Line, Ambala City has been visually inspected by the Sub Divisional Engineer, Provincial Sub Division No.7 alongwith JE incharge and who have reported that building is found safe for running school. The school Building Safety Certificate is hereby given upto the period 2022 – 23 with the following conditions:-

1. Building of this School should be repaired every year.
2. Water should not be allowed to stagnate around and on the roof of the Building.
3. If Building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
4. Institution will be responsible for safety of building from every angle and Fire-Fighting equipment should be in functional condition.
5. If the building of the school is to be extended, the same should be first approved from Structural Engineer.
6. Proof Checked Strutral Drawings should be submitted to this office for record within one month after issuing the NOC.
7. Adequate Fire safety may be adopted in the school campus.
8. Institute shall also ensure safety precautions from false ceiling and vitrified tiles used in dado.
9. NOC may be considered as cancelled by this office if the School violates any of the above points.

This is for your kind information.

DA/NIL

W
Executive Engineer,
Provincial Division No.1,
PWD B&R Br; Ambala Cantt.

Endst. No.

Dated:-

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No. 7, PWD B&R Br; Ambala Cantt for information w.r.t. his office No. 2066 dated 28.12.2022.

DA/ NIL

W
Executive Engineer,
Provincial Division No.1,
PWD B&R Br; Ambala Cantt.